



Subject: Compact Disk (CD) of [ACAЕ - LOVAG Certificate of conformity](#)

Please take note that only the document in paper format shall be considered as the authentic ACAЕ – LOVAG Certificate of conformity.

**ACAЕ – General Secretary
Dr.Eng. Mauro Marchi**

A handwritten signature in black ink, appearing to read "Mauro Marchi", written in a cursive style.



ASSOCIAZIONE PER LA CERTIFICAZIONE
DELLE APPARECCHIATURE ELETTRICHE

Via Tito Livio, 5 – 24123 – BERGAMO (Italy)
Tel. +390354175244 fax. +390354534662 e-mail:acaecert@tin.it



Certificate of Conformity

LOVAG-Certificate No. **IT 12.029**

Page 1 of 1

Apparatus

Low voltage switchgear assembly – 3 phases + neutral – 690 V (U_o) – 1000V (U_i) – 3500A (I_{nA}) – 80kA 1sec. (I_{cw}) – frequency 50/60Hz

Designation

CQE

Manufacturer or responsible vendor

DKC Europe s.r.l

Via Libertà, 207

28043 Bellinzago Novarese (NO) - Italy

Tested for: DKC Europe s.r.l

Tested by: ACAE Laboratory IV 01

The apparatus, constructed in accordance with the description mentioned in the Test Report listed on this Certificate has been subjected to the series of proving tests in accordance with IEC 61439-1 (2011-08) and 61439-2 Ed.2.0 (2011-08).

- Verification of the short-circuit withstand strength (10.11)

The results are shown in the Test Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer as stated below.


Rated short-time withstand current (I_{cw}):
80kA – 1sec.

This document includes Test report No. : 6670/VNL
Issue date: 2012.03.30

Responsible Certification Body : ACAE
Mauro Marchi



PRD N°070B
Signatory of EA, IAF and ILAC
Mutual Recognition Agreements



Authorized signature

Date: 2012.04.04

This certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designation with that tested rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition.

The responsible certification body as member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Test Instructions wherever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the tests performed and the assigned rated characteristics of the apparatus Tested, are permitted without written permission from the LOVAG Signatory responsible for this Certificate.

the expiry of this certificate see ACAE certification scheme.

